

Water Quality Chemistry Services
 Lead School Testing
 Report Date: 28-Apr-2017

San Diego Unified School District
ALBA High School

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168017	4/22/2017	6:47 AM	SAMPLE 1	3710020-AHH-A	< 5	µg/L
W1168018	4/22/2017	6:35 AM	SAMPLE 2	3710020-AHH-B	< 5	µg/L
W1168019	4/22/2017	6:45 AM	SAMPLE 3	3710020-AHH-C	< 5	µg/L
W1168020	4/22/2017	6:39 AM	SAMPLE 4	3710020-AHH-D	< 5	µg/L
W1168021	4/22/2017	6:42 AM	SAMPLE 5	3710020-AHH-E	< 5	µg/L

- | <u>Source</u> | <u>Source Description</u> |
|---------------|---|
| SAMPLE 1 | Main office Bldg.; Nurse's office; single bubbler on the right side of the sink inside the office |
| SAMPLE 2 | Classroom building; Lunch patio area on Exterior North Wall; Upper left bubbler of 2 single fountains |
| SAMPLE 3 | Kitchen, two compartment sink, faucet |
| SAMPLE 4 | Classroom building; Room 4; Single bubbler on the r side of the interior sink |
| SAMPLE 5 | Classroom building; Room 10; Single bubbler on the r side of the interior sink |

DRL=State Mandated Detection Limit for Reporting (DLR)= 5 µg/L
 Action Level (AL) = 15 µg/L



Doug Campbell, Senior Chemist