



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A. San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 4/12/17

San Diego Unified School District

Baker Elementary School

Sample ID	Sample Date	Sample Time	Description	External ID	Lead	Units
W1164083	04/04/17	06:05 AM	SAMPLE 1	3710020-AAI-A	< 5	ug/L
W1164084	04/04/17	06:08 AM	SAMPLE 2	3710020-AAI-B	< 5	ug/L
W1164085	04/04/17	06:11 AM	SAMPLE 3	3710020-AAI-C	< 5	ug/L
W1164086	04/04/17	06:15 AM	SAMPLE 4	3710020-AAI-D	< 5	ug/L
W1164087	04/04/17	06:18 AM	SAMPLE 5	3710020-AAI-E	< 5	ug/L

- SAMPLE 1 Admin/Auditorium btwn K1 & K2 restrooms right bubbler
- SAMPLE 2 Admin BLDG. btwn electrical meter rm & hallway door, right, tall bubbler
- SAMPLE 3 1-5 Supply Rm. near girls restroom & supply rm. upper right bubbler
- SAMPLE 4 7-12 next to custodian ups sign & girls restroom, left bubbler
- SAMPLE 5 Field Restrooms, outside bungalow restroom near sports field, lower right bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist