



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A. San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 4/12/17

San Diego Unified School District

Encanto Elementary School

Sample ID	Sample Date	Sample Time	Description	External ID	Lead	Units
W1163952	04/04/17	05:45 AM	SAMPLE 1	3710020-AAJ-A	5.15	ug/L
W1163953	04/04/17	05:50 AM	SAMPLE 2	3710020-AAJ-B	< 5	ug/L
W1163954	04/04/17	05:55 AM	SAMPLE 3	3710020-AAJ-C	5.73	ug/L
W1163955	04/04/17	06:00 AM	SAMPLE 4	3710020-AAJ-D	9.19	ug/L
W1163956	04/04/17	06:05 AM	SAMPLE 5	3710020-AAJ-E	< 5	ug/L

Sample # Sample Site

- SAMPLE 1 400 BLDG, outside wall bubbler, right bubbler
- SAMPLE 2 300 BLDG, lower level SW corner of building, right bubbler
- SAMPLE 3 200 BLDG, lower level SW corner
- SAMPLE 4 200 BLDG, upper level SW corner
- SAMPLE 5 100 BLDG, upper level SW corner

DLR= State Mandated Detection Limit for Reporting (DLR)= 5
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist