



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A, San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 4/27/17

San Diego Unified School District  
**Gage Elementary**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1166639	04/14/17	06:05 AM	SAMPLE 1	3710020-AEF-C	5.21	ug/L
W1166640	04/14/17	06:05 AM	SAMPLE 2	3710020-AEF-D	10.1	ug/L
W1166641	04/14/17	06:10 AM	SAMPLE 3	3710020-AEF-E	< 5	ug/L
W1166642	04/14/17	06:15 AM	SAMPLE 4	3710020-AEF-A	< 5	ug/L
W1166643	04/14/17	06:15 AM	SAMPLE 5	3710020-AEF-B	< 5	ug/L

- | <u>Source</u> | <u>Source Description</u>   |
|---------------|---|
| SAMPLE 1      | 200, room K-2, bubbler at sink  |
| SAMPLE 2      | BLDG 200, west corner, next to K-3 and girls RR, triple fountain, left bubbler          |
| SAMPLE 3      | BLDG 300, east side, between girls RR and custodial room, right fountain single bubbler |
| SAMPLE 4      | BLDG 4, room B-8, bubbler at sink   |
| SAMPLE 5      | BLDG 5, lunch court, single bubbler left of hand sink                                   |

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L  
Action Level (AL) = 15 ug/L

  
Tom Burger, Associate Chemist