



# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Mt. Everest Academy

Report Type: Progress Report

Date of Report: 4/16/2019

Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
1 3 Admin - Mt. Everest_01-03 Workroom, West Wall	DWO-299-001	Faucet	2.08		
2 3 Admin - Mt. Everest_01-03 Lounge, North Wall	DWO-299-002	Faucet	1.97		
3 4 Classrooms 1-6/Supply - Mt. Everest_01-04 Classroom - 01, West Wall	DWO-299-003	Drinking Fountain Bubblers	7.30		
4 4 Classrooms 1-6/Supply - Mt. Everest_01-04 Classroom - 02, East Wall	DWO-299-004	Drinking Fountain Bubblers	4.84		
5 4 Classrooms 1-6/Supply - Mt. Everest_01-04 Classroom - 03, West Wall	DWO-299-007	Drinking Fountain Bubblers	5.91		
6 4 Classrooms 1-6/Supply - Mt. Everest_01-04 Classroom - 06, West Wall	DWO-299-008	Drinking Fountain Bubblers	2.71		
7 4 Classrooms 1-6/Supply - Mt. Everest_01-04 Classroom - 05, East Wall	DWO-299-009	Drinking Fountain Bubblers	6.81		
8 4 Classrooms 1-6/Supply - Mt. Everest_01-04 Classroom - 04, West Wall	DWO-299-010	Drinking Fountain Bubblers	4.82		
9 4 Classrooms 1-6/Supply - Mt. Everest_01-04 Building Exterior, West Wall	DWO-299-011	Drinking Fountain Bubblers	<5		
10 4 Classrooms 1-6/Supply - Mt. Everest_01-04 Building Exterior, West Wall	DWO-299-012	Drinking Fountain Bubblers	2.42		
11 5 Classrooms 7-12 - Mt. Everest_01-05 Classroom - 07, West Wall	DWO-299-013	Drinking Fountain Bubblers	<5		
12 5 Classrooms 7-12 - Mt. Everest_01-05 Classroom - 08, East Wall	DWO-299-014	Drinking Fountain Bubblers	10.30		
13 5 Classrooms 7-12 - Mt. Everest_01-05 Classroom - 09, West Wall	DWO-299-015	Drinking Fountain Bubblers	5.39		
14 5 Classrooms 7-12 - Mt. Everest_01-05 Classroom - 12, West Wall	DWO-299-016	Drinking Fountain Bubblers	6.34		
15 5 Classrooms 7-12 - Mt. Everest_01-05 Classroom - 11, East Wall	DWO-299-017	Drinking Fountain Bubblers	4.94		
16 5 Classrooms 7-12 - Mt. Everest_01-05 Classroom - 10, West Wall	DWO-299-018	Drinking Fountain Bubblers	5.90		



# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Mt. Everest Academy

Report Type: Progress Report

Date of Report: 4/16/2019

	Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
17	5 Classrooms 7-12 - Mt. Everest_01-05 Building Exterior, West Wall	DWO-299-020	Drinking Fountain Bubblers	<5		
18	5 Classrooms 7-12 - Mt. Everest_01-05 Building Exterior, West Wall	DWO-299-021	Drinking Fountain Bubblers	2.75		
19	Portable B06 - Mt. Everest Offices - B06, North Wall	DWO-299-022	Faucet	ND		
20	Portable B05 - Mt. Everest Offices - B05, East Wall	DWO-299-023	Faucet	1.32		
21	Portable B04 - Mt. Everest Offices - B04, East Wall	DWO-299-024	Faucet	1.06		
22	Portable B03 - Mt. Everest Offices - B03, East Wall	DWO-299-025	Faucet	ND		
23	Portable B02 - Mt. Everest Offices - B02, East Wall	DWO-299-026	Faucet	1.05		
24	Portable B01 - Mt. Everest Offices - B01, East Wall	DWO-299-027	Faucet	1.00		
25	1 Classrooms 13-14 - Mt. Everest_01-01 Classroom - 14 Eye & Otology, East Wall	DWO-299-028	Faucet	20.40		
26	1 Classrooms 13-14 - Mt. Everest_01-01 Building Exterior, West Wall	DWO-299-029	Drinking Fountain Bubblers	5.03		
27	1 Classrooms 13-14 - Mt. Everest_01-01 Building Exterior, West Wall	DWO-299-030	Drinking Fountain Bubblers	9.62		
28	2 Auditorium/Cafeteria - Mt. Everest_01-02 Building Exterior, South Wall	DWO-299-031	Drinking Fountain Bubblers	<5		
29	2 Auditorium/Cafeteria - Mt. Everest_01-02 Building Exterior, South Wall	DWO-299-032	Drinking Fountain Bubblers	4.12		
30	2 Auditorium/Cafeteria - Mt. Everest_01-02 Science Prep, east Wall	DWO-299-033	Spray Faucet	1.32		
31	3 Admin - Mt. Everest_01-03 Assessment Rm 1, North Wall	DWO-299-034	Faucet	2.26		

\*Action levels and color indication



# SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING REPORT

Facility: Mt. Everest Academy

Report Type: Progress Report

Date of Report: 4/16/2019

Location	DWO No	Type	Initial Result*	Action Taken**	Clearance Result
----------	--------	------	-----------------	----------------	------------------

*Federal action level is above 15ppb (parts per billion). SDUSD uses an action level that is stricter and includes anything above 5 PPB. Items indicated in green are below District action level. Items indicated in yellow are above District action level. Items indicated in red are above both District and Federal action levels. Green indicates no action needed. Red/Yellow indicates action needed.*

**\*\*Clearance actions**

INIT=Initial result cleared no action needed. FLTR=Filter has been installed. PLMB=Plumbing work performed. RRC=Repeat and repeat-confirmation testing has been performed and both samples yielded results below District action level. RMOV=The drinking water outlet has been removed from service.