



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A. San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 4/12/17  
San Diego Unified School District  
**Mann Middle School**

Sample ID	Sample Date	Sample Time	Description	External ID	Lead	Units
W1164430	04/06/17	06:01 AM	SAMPLE 1	3710020-ABG-A	< 5	ug/L
W1164431	04/06/17	06:06 AM	SAMPLE 2	3710020-ABG-B	6.98	ug/L
W1164432	04/06/17	06:08 AM	SAMPLE 3	3710020-ABG-C	9.31	ug/L
W1164433	04/06/17	06:10 AM	SAMPLE 4	3710020-ABG-D	< 5	ug/L
W1164434	04/06/17	06:18 AM	SAMPLE 5	3710020-ABG-E	< 5	ug/L

- SAMPLE 1 BLDG 100, Main Office, far left bubbler (312-1)
- SAMPLE 2 Cafeteria BLDG, east side, triple fountain, center bubbler
- SAMPLE 3 BLDG 300, next to custodian, single bubbler
- SAMPLE 4 Kitchen interior back wall, back sink, faucet
- SAMPLE 5 BLDG 600, underneath cover outside, center bubbler

DLR= State Mandated Detection Limit for Reporting (D)  
Action Level (AL) = 15 ug/L

  
Doug Campbell, Senior Chemist