



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/4/17


San Diego Unified School District
Marshall Middle

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1169333	04/29/17	05:42 AM	SAMPLE 1	3710020-BCJ-A	< 5	ug/L
W1169334	04/29/17	05:37 AM	SAMPLE 2	3710020-BCJ-B	< 5	ug/L
W1169335	04/29/17	05:47 AM	SAMPLE 3	3710020-BCJ-C	< 5	ug/L
W1169336	04/29/17	05:50 AM	SAMPLE 4	3710020-BCJ-D	< 5	ug/L
W1169337	04/29/17	05:53 AM	SAMPLE 5	3710020-BCJ-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 PE building, Boys end, between boys & girls RR, two single bubbler fountains, lower right fountain
- SAMPLE 2 Multi-Purpose Room, outside between boys & girls RR, two single bubbler fountains, upper right fountain
- SAMPLE 3 Building C, Outside lower floor east wall, two single bubbler fountains, upper left fountain
- SAMPLE 4 Building A, Outside east wall lowest level, two single bubbler fountains, upper left fountain
- SAMPLE 5 Building B, Lowest level east wall, two single bubbler fountains, upper left fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist