



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 4/27/17

San Diego Unified School District
Memorial Scholars & Athletes

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1166747	04/14/17	06:27 AM	SAMPLE 1	3710020-AFB-A	< 5	ug/L
W1166748	04/14/17	06:37 AM	SAMPLE 2	3710020-AFB-B	< 5	ug/L
W1166749	04/14/17	06:30 AM	SAMPLE 3	3710020-AFB-C	< 5	ug/L
W1166750	04/14/17	06:42 AM	SAMPLE 4	3710020-AFB-D	< 5	ug/L
W1166751	04/14/17	06:40 AM	SAMPLE 5	3710020-AFB-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 King-Chávez Academy Classroom Bldg. 600;N wall;interior swing arm faucet at 2-compartment sink
- SAMPLE 2 Exterior south wall of food Service Bldg.;Right bubbler on double fountain
- SAMPLE 3 Physical Ed. Bldg. 700; Exterior north wall;Right bubbler on triple fountain
- SAMPLE 4 Media Center Bldg. 300; Exterior North wall; Left/lower bubbler of 2 separate single fountains.
- SAMPLE 5 Auditorium Bldg. 100; Exterior North wall; : Left bubbler on double fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Tom Burger, Associate Chemist