



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A, San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 5/26/17

San Diego Unified School District  
**Ocean Beach Elementary**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1172393	05/17/17	06:08 AM	SAMPLE 1	3710020-BHF-A	< 5	ug/L
W1172394	05/17/17	06:11 AM	SAMPLE 2	3710020-BHF-B	< 5	ug/L
W1172395	05/17/17	06:15 AM	SAMPLE 3	3710020-BHF-C	< 5	ug/L
W1172396	05/17/17	06:19 AM	SAMPLE 4	3710020-BHF-D	5.31	ug/L
W1172397	05/17/17	06:01 AM	SAMPLE 5	3710020-BHF-E	< 5	ug/L

**Source**      **Source Description**

- SAMPLE 1      Rms 1-3 bldg, Cafeteria, Sink in the Prep Kitchen, next to Office, facing island prep, kitchen faucet above single compartment sink
- SAMPLE 2      Rms 7-8 bldg, Wall mounted exterior (South of Bldg), facing new lunch arbor, two single bubbler fountains, lower left fountain
- SAMPLE 3      Rms 2-6 bldg, Wall mounted exterior (South of Bldg), facing tree & blacktop before the old lunch arbor, two single bubbler fountains, lower left fountain
- SAMPLE 4      Rms 20-21, classroom sink, between Girls & Boys RRs, dual sinks, bubbler on right sink
- SAMPLE 5      Kindergarten, Wall mounted Exterior (West of Bldg), between K1 & K2, facing blacktop/playground, two single bubbler fountains, lower left fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L  
Action Level (AL) = 15 ug/L

  
Doug Campbell, Senior Chemist