



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 4/27/17


San Diego Unified School District
Paradise Hills Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1166147	04/13/17	06:05 AM	SAMPLE 1	3710020-AEA-A	< 5	ug/L
W1166148	04/13/17	06:10 AM	SAMPLE 2	3710020-AEA-B	< 5	ug/L
W1166149	04/13/17	06:15 AM	SAMPLE 3	3710020-AEA-C	< 5	ug/L
W1166150	04/13/17	06:15 AM	SAMPLE 4	3710020-AEA-D	< 5	ug/L
W1166151	04/13/17	06:20 AM	SAMPLE 5	3710020-AEA-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 Cafeteria, inside kitchen, wall adjacent to parking lot, 2 compartment sink, faucet (229-01)
- SAMPLE 2 Admin BLDG, room 2, bubbler at sink (229-02)
- SAMPLE 3 Admin BLDG, exterior wall of boys restroom, near supply room, left bubbler on double fountain (229-03)
- SAMPLE 4 Admin BLDG, exterior wall of girls restroom, near room 11, right bubbler on triple fountain (229-04))
- SAMPLE 5 BLDG 900, exterior of room 8 facing playground, left lower bubbler (229-05)

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist