



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 6/8/17

San Diego Unified School District
Pacific Beach Middle

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1170253	05/17/17	06:09 AM	SAMPLE 1	3710020-BFH-A	< 5	ug/L
W1170254	05/17/17	06:02 AM	SAMPLE 2	3710020-BFH-B	< 5	ug/L
W1170255	05/17/17	06:05 AM	SAMPLE 3	3710020-BFH-C	< 5	ug/L
W1170256	05/17/17	06:13 AM	SAMPLE 4	3710020-BFH-D	< 5	ug/L
W1170257	05/17/17	06:17 AM	SAMPLE 5	3710020-BFH-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 Office, Outside right side of entrance to main office door, Single bubbler drinking fountain
- SAMPLE 2 Kitchen, Inside kitchen, single compartment sink to the left of larger sink, kitchen faucet above sink
- SAMPLE 3 Pit /Library, Outside at wall across from Kitchen in Lunch patio area near green door, Single bubbler drinking fountain
- SAMPLE 4 100 Bldg. Down Stairs, south side inside building hallway on the right near double door exit, single bubbler fountain to the left of dual fountain
- SAMPLE 5 Gym- Girls Locker, Outside west end of girls' gym near basketball court, triple bubbler fountain, left bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist