

Water Quality Chemistry Services  
 Lead School Testing  
 Report Date: 28-Apr-2017

San Diego Unified School District  
**San Diego Global Vision Academy**

| Sample ID | Sample Date | Sample Time | Source   | External ID   | Lead | Units |
|-----------|-------------|-------------|----------|---------------|------|-------|
| W1167446  | 4/20/2017   | 5:59 AM     | SAMPLE 1 | 3710020-AHF-A | < 5  | µg/L  |
| W1167447  | 4/20/2017   | 6:01 AM     | SAMPLE 2 | 3710020-AHF-B | < 5  | µg/L  |
| W1167448  | 4/20/2017   | 6:03 AM     | SAMPLE 3 | 3710020-AHF-C | < 5  | µg/L  |
| W1167449  | 4/20/2017   | 6:05 AM     | SAMPLE 4 | 3710020-AHF-D | < 5  | µg/L  |
| W1167450  | 4/20/2017   | 5:53 AM     | SAMPLE 5 | 3710020-AHF-E | < 5  | µg/L  |

| <u>Source</u> | <u>Source Description</u>  |
|---------------|--|
| SAMPLE 1      | Room 102, bubbler at classroom sink/faucet with push button cap  |
| SAMPLE 2      | Room 104, bubbler at classroom sink/faucet with push button cap  |
| SAMPLE 3      | Room 105, bubbler at classroom sink/faucet with push button cap  |
| SAMPLE 4      | Room 107, bubbler at classroom sink/faucet with push button cap  |
| SAMPLE 5      | Exterior, near grass area by 35th Street, floor mounted cement stand with two single bubbler fountains, upper fountain |

DRL=State Mandated Detection Limit for Reporting (DLR)= 5 µg/L  
 Action Level (AL) = 15 µg/L



Doug Campbell, Senior Chemist